



KEYNOTES

- 20 GA VERO W3 FORMLOCK DECK W/ 6 1/2" (TOTAL THICKNESS) CONC SLAB W/ #4 @ 10" OC EA WAY
- CABLE TRAY INSERTS, SEE 4/SB.4 & ARCH. GRAVITY & LATERAL SUPPORT BY OTHERS
- NOT USED
- 22 GA HSB-36 ROOF DECK OVERBUILD W/ BP SIDE SEAMS @ 2'-0" OC
- ROOF OVERBUILD SUPPORTS. SPACE PONY WALLS @ 6'-0" OC MAX. SEE 3 & 4/SB.5
- EXISTING OPEN WEB MTL JOIST
- EXISTING 2x SUBPURLINS
- EXISTING PLYWOOD ROOF SHEATHING
- 4x8 #2 DFL BLOCKING, PROVIDE COIL STRAP ALONG BLOCKING PER 9/SB.3
- PROVIDE (3) SIMPSON HTT22 AT EXISTING WALL PANEL. SEE 9/SB.3
- 8" CMU - SEE 2, 8 & 12/SB.5, SEE ARCH FOR EXTENT

PLAN NOTES

- SEE ARCHITECTURAL DRAWINGS FOR CONTROL ELEVATIONS
- SEE SHEET S5.1 FOR FRAME ELEVATIONS
- SEE DETAIL 2/SB.4 FOR DECK BEARING ANGLES AT COLUMNS
- * INDICATES SPECIAL BEAM CONNECTION PER 3/SB.4
- ⊠ INDICATES SPECIAL BEAM CONNECTION PER 11/SB.5

LEGEND

- BEAM SIZE
W21x44 [30] c=1/2"
OF 3/4" HWS PER SPAN EQ SP
CAMBER
- BEAM SIZE
W21x44 [18/1/18]
OF 3/4" HWS BETWEEN EA PAIR BMS FRAMING IN
- CONCRETE TILT PANEL
- CMU WALL PER S2.1

GROUP MACKENZIE
 Architecture
 Interior Design
 Land Use Planning
 Civil Engineering
 Structural Engineering
 Transportation Planning

0690 SW Bancroft St / PO Box 6039
 Portland, OR 97201-0039
 Tel: 503.224.9500 / 360.95.7879 Fax: 503.228.1285

Client

AT&T

Project
BROADBAND FACILITY EXPANSION PHASE 2 AND 3

TROUTDALE, OREGON

STRUCTURAL REGISTERED PROFESSIONAL ENGINEER
 10,928
 OREGON
 NOV 16, 1995
 MARK HETTUM
 EXPIRES: 6/30/03

© GROUP MACKENZIE 2002
 ALL RIGHTS RESERVED
 THESE DRAWINGS ARE THE PROPERTY OF GROUP MACKENZIE AND ARE NOT TO BE USED OR REPRODUCED IN ANY MANNER, WITHOUT PRIOR WRITTEN PERMISSION

REVISIONS:

REVISION	LAST REVISION THIS SHEET	REVISION EDITION	CLOSING DATE
A	NONE	07/30/2002	
B	NONE	08/12/2002	
C	22	09/13/2002	

SHEET TITLE:
ROOF FRAMING PLAN

FIRST ISSUED:
 LAST ISSUED:
 DRAWN BY:
 CHECKED BY: JSA
 SHEET:

1
S2.2 1/8"=1'-0"

S2.2

INCLUDES REVISION C
 ISSUED FOR BID 7/3/02
 JOB NO. 990276.01